

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-0854:0105

Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: Protectowire60 Washington Street, Pembroke, MA 02359
Contact: Jim Goggin (781) 826-3878 Fax (781) 826-2045
Email: jgoggin@protectowire.com

DESIGN: Model CTI Linear Heat Detectors and CTM-530 Interface Module. Model designation identifies operating temperature ratings: CTI-155 (155°F), CTI-190 (190°F), CTI-220 (220°F), CTI-280 (280°F) and CTI-356 (356°F). Models may have suffixes R or X for alternate outer jacket materials. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12 or 24 Vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, operating temperature and FM label.

APPROVAL: Listed as linear heat detectors for use with listed fire alarm control panels. Refer to manufacturer's Installation Manual for details.

04-16-15 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **June 30, 2019**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division