

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

SA5100-700 Soteria Analogue Addressable Class A1R Optical Smoke/Heat Detector with Short Circuit Isolator

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

and produced in the manufacturing plant:

Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-5:2000/A1:2002 : **Fire detection and fire alarm systems - Part 5: Heat detectors - Point detectors**
EN 54-7:2000/A1:2002/A2:2006 : **Fire detection and fire alarm systems - Part 7: Smoke detectors - Point detectors using scattered light, transmitted light or ionization**
EN 54-17:2005 : **Fire detection and fire alarm systems - Part 17: Short-circuit isolators**

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: **2019-10-09**.

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

This certificate was first issued 2019-10-09.



Merete Poulsen
Responsible for evaluation



Allan Laursen
Responsible for certification decision

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Annex 1

EXTENT

Type:

SA5100-700 Soteria Analogue Addressable Class A1R Optical Smoke/Heat Detector with Short Circuit Isolator

Variant:

SA5100-700LIM Optical Smoke/Heat Detector with Short Circuit Isolator

Bases:

SA5000-200 Addressable XPERT 8 Mounting Base

45681-210 XP95 Mounting Base

Notes:

Certified at the following settings:

Mode 1: High sensitivity smoke detector with high heat enhancement

Mode 2: Standard smoke sensitivity only

Mode 3: Medium sensitivity smoke detector with medium heat enhancement

Mode 4: Low sensitivity smoke detector with high heat enhancement

Mode 5: Class A1R heat detector

Performance

Essential characteristics	Clauses in EN 54-5:2000	Performance
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions	4.2, 4.3, 5.2 to 5.6, 5.8, 6.1, 6.2 (6.1 only Suffix S det./6.2 only Suffix R det.)	Pass
Operational reliability	4.4 to 4.11	Pass
Tolerance to supply voltage	5.7	Pass
Durability of operational reliability and response delay; temperature resistance	5.9, 5.10	Pass
Durability of operational reliability; vibration resistance	5.14 to 5.17	Pass
Durability of operational reliability; humidity resistance	5.11, 5.12	Pass
Durability of operational reliability; corrosion resistance	5.13	Pass
Durability of operational reliability; electrical stability	5.18	Pass

Essential characteristics	Clauses in EN 54-7:2000	Performance
Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions	4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18	Pass
Operational reliability	4.2 to 4.7, 4.9 to 4.11	Pass
Tolerance to supply voltage	5.5	Pass
Durability of operational reliability and response delay; temperature resistance	5.8, 5.9	Pass
Durability of operational reliability; vibration resistance	5.13 to 5.16	Pass
Durability of operational reliability; humidity resistance	5.10, 5.11	Pass
Durability of operational reliability; corrosion resistance	5.12	Pass
Durability of operational reliability; electrical stability	5.17	Pass

The certificate shall be reproduced in extenso
 – extracts only with written permission from DBI Certification A/S.

Essential characteristics	Clauses in EN 54-17:2005	Performance
Performance under fire conditions	5.2 1)	Pass
Operational reliability	4	Pass
Durability of operational reliability; temperature resistance	5.4, 5.5	Pass
Durability of operational reliability; vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability; humidity resistance	5.6, 5.7	Pass
Durability of operational reliability; corrosion resistance	5.8	Pass
Durability of operational reliability; electrical stability	5.3, 5.13	Pass
1) This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices		

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.

Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
BRE BRE BRE	P101798 Issue: 1 TE 295788-SW TE295788-1	23 October 2015 15 October 2014 30 April 2015

TECHNICAL BASIS

File Number	Title
SA5100-700 45681-210 SA5000-200	Build Standard Build Standard Build Standard

The certificate shall be reproduced in extenso
– extracts only with written permission from DBI Certification A/S.