

Certificate of Constancy of Performance

0359-CPR-00037



In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation), this certificate applies to the construction product(s).

Product(s): **XPander Wireless Detector Bases**
(refer to attached appendix for details and conditions)

Produced by or for: **Apollo Fire Detectors Limited**
36 Brookside Road, Havant, Hampshire, PO9 1JR

Produced in the manufacturing plant(s): **EMS Security Group Limited**
Technology House, Sea Street, Herne Bay, Kent, CT6 8JZ

Intended use: **Fire Safety**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s):

EN54-25:2008+AC:2012

Fire detection and fire alarm systems. Fire detection and fire alarm systems - Components using radio links

Under system 1 are applied and that the product(s) fulfils all the prescribed requirements set out above.

This certificate was first issued under CPD (89/106/EEC) on **24 June 2010** and re-issued on **2 December 2014** under CPR (305/2011/EU) and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body. A review of the product(s) and compliant standard(s) will be carried out after 5 years to ensure continued compliance.



Notified Body
0359

Intertek Testing & Certification Limited
Cleeve Road, Leatherhead
Surrey, KT22 7SB
Tel: +44 (0)1372 370900
Fax: +44 (0)1372 370977
E-mail: cpd.uk@intertek.com

Oliver Richardson
Operations Manager

Date 2/12/2014
Issue 1
Review date 24/6/2015

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability is limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for a expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by

Certificate of Constancy of Performance

0359-CPR-00037



Appendix to Certificate of Constancy of Performance 0359-CPR-00037

The details and condition of use for the XPander Wireless Detector Base XPA-WB-10022-APO, placed on the market by:

Apollo Fire Detectors Limited

36 Brookside Road, Havant, Hampshire, PO9 1JR

Variants:

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (where applicable):

Detectors:

XPander Class A1R Heat Detector, Part No. XPA-HT-11170-APO

XPander Class CS Heat Detector, Part No. XPA-HT-11171-APO

XPander Photoelectric Smoke Detector, Part No. XPA-OP-12034-APO

XPander Multisensor Smoke Detector, Part No. XPA-OH-13032-APO

Conditions of use:

Suitable for indoor applications

General Notes:

1. Evaluated under Intertek project numbers;
G09042160 for the XPander Detector Base XPA-WB-10022-APO
2. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB
Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00037
Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex,
CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Certificate of Constancy of Performance

0359-CPR-00037



Appendix to Certificate of Constancy of Performance 0359-CPR-00037 (continued)

<i>Table of performance for EN54-25:2008+AC:2012</i>			
Harmonised technical specification			
Essential characteristics	Performance	Clauses	Notes
Performance parameters under fire conditions	Pass	4.1, 4.2.2, 5.2, 8.3.7	a
Response delay (response time to fire)	Pass	8.2.3, 8.2.6	a
Operational reliability	Pass	4.2.1, 4.2.3 to 4.2.7, 5.3, 5.4, 6, 7, 8.2.2, 8.2.4, 8.2.5, 8.2.7, 8.2.8, 8.2.9, 8.3.1, 8.3.2, 8.3.3, 8.3.4, 8.3.5, 8.3.6	
Durability of operational reliability; temperature resistance	Pass	8.3.9, 8.3.10, 8.3.11	
Durability of operational reliability; vibration resistance	Pass	8.3.16, 8.3.17 to 8.3.19	
Durability of operational reliability; humidity resistance	Pass	8.3.12, 8.3.13, 8.3.14	b
Durability of operational reliability; corrosion resistance	Pass	8.3.15	
Durability of operational reliability; electrical stability	Pass	8.3.20	c
Notes:			
<p>a. <i>The products covered by this standard are assumed to enter the alarm condition, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire.</i></p> <p>b. <i>Clause 8.3.13 is only applicable for CIE and smoke detectors.</i></p> <p>c. <i>Clauses 8.3.20.2f and 8.3.20.2g are only applicable for mains supplied devices; these clauses were therefore not assessed.</i></p>			

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB
 Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00037
 Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex,
 CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.